Environment Department Occupational Health and Safety Bureau 525 Camino de los Marquez, Suite 3 Santa Fe NM 87505

Phone: (505) 476-8700 Fax: (505) 476-8734



Citation and Notification of Penalty

To: Inspection Number: 1687441

Hellbent Construction, LLC. Inspection Date(s): 07/31/2023-07/31/2023

Issuance Date: 01/29/2024

AND ITS SUCCESSORS 2284 Henry Lynch Rd. #79 Santa Fe, NM 87507

Inspection Site:

4 Dovela Ct. Santa Fe, NM 87508 The violation(s) described in this Citation and Notification of Penalty is (are) alleged to have occurred on or about the day(s) the inspection was made unless otherwise indicated within the description given below.

This Citation and Notification of Penalty (this Citation) describes violations of the Occupational Safety and Health Act of 1970. The penalty(ies) listed herein is (are) based on these violations. You must abate the violations referred to in this Citation by the dates listed and pay the penalties proposed, unless within 15 working days (excluding weekends and Federal holidays) from your receipt of this Citation and Notification of Penalty you mail a notice of contest to the Environment Department, Occupational Health and Safety Bureau at the address shown above. Issuance of this Citation does not constitute a finding that a violation of the Act has occurred unless there is a failure to contest as provided for in the Act or, if contested, unless this Citation is affirmed by the Review Commission or a court.

Posting-The law requires that a copy of this Citation and Notification of Penalty be posted immediately in a prominent place at or near the location of the violation(s) cited herein, or, if it is not practicable because of the nature of the employer's operations, where it will be readily observable by all affected employees. This Citation must remain posted until the violation(s) cited herein has (have) been abated, or for 3 working days (excluding weekends and Federal holidays), whichever is longer. The penalty dollar amounts need not be posted and may be marked out or covered up prior to posting.

Informal Conference- An informal conference is not required. However, at the request of an employer, affected employee, or representative of employees, the Bureau Chief or the Bureau Chiefs designee may hold an informal conference. At this conference any issues raised by an inspection, citation, proposed penalty, proposed petition for modification of abatement date or proposed petition for variance may be discussed. If you intend to request an informal conference, take care to schedule it early enough to allow time to contest after the informal conference discussion, should you decide to do so.

When the conference is requested by an employer, an affected employee or representative shall be afforded an opportunity to participate, at the discretion of the Bureau Chief or Bureau Chiefs designee. When the conference is requested by an employee or representative of employees, the employer shall be afforded an opportunity to participate, at the discretion of the Bureau Chief or Bureau Chiefs designee.

The request for an informal conference and the informal conference meeting shall not extend or modify in any manner:

- 1) an abatement date established in the citation:
- 2) the deadline for an employer to file a notice of contest;
- 3) any other filing deadline related to the citation; or
- 4) any matter pending before the bureau.

See pages 1 through 3 of this Citation and Notification of Penalty for information on employer and employee rights and responsibilities.

Once an employer files a notice of contest, a petition for modification of the abatement date, a request for a commission hearing, a petition for variance, or other filing with the Occupational Health and Safety Review Commission or the Environment Department, the opportunity for an informal conference is no longer available.

Right to Contest- You have the right to contest this Citation and Notification of Penalty. You may contest all citation items or only individual items. You may also contest proposed penalties and/or abatement dates without contesting the underlying violations. Unless you inform the Bureau Chief in writing that you intend to contest the citation(s) and/or proposed penalty(ies) within 15 working days after receipt, the citation(s) and the proposed penalty(ies) will become a final order of the Occupational Safety and Health Review Commission and may not be reviewed by any court or agency. It is recommended that the Notice of Contest be filed via "Certified Mail".

Penalty Payment- Penalties are due within 15 working days of receipt of this notification unless contested. Make your check or money order payable to the Environment Department, Occupational Health and Safety Bureau. Please indicate the Inspection Number on the remittance.

OSHA does not agree to any restrictions or conditions or endorsements put on any check or money order for less than the full amount due, and will cash the check or money order as if these restrictions, conditions, or endorsements do not exist.

Notification of Corrective Action - For violations which you do not contest, you should notify the Occupational Health and Safety Bureau (OHSB) that each cited violation has been abated. To certify abatement, you should complete the "Description of Corrective Action Taken" box which follows each citation and sign the statement on the last citation page. You are not required to certify abatement if the compliance officer observed that abatement has occurred during the on-site inspection. The citation may indicate that you should submit additional documentation such as photographs, purchase orders, copies of written programs, etc. Failure to return all completed forms and documents to the Program Manager no later than 10 days after the abatement date may result in additional penalties.

You are also required to inform your employees about abatement activities by posting a copy of each document submitted to OHSB or a summary of the document near the place where the violation occurred. Documents <u>must remain posted for 3</u> working days after submission to OHSB.

Employer Discrimination Unlawful- The law prohibits discrimination by an employer against an employee for filing a complaint or for exercising any rights under this Act. An employee who believes that he/she has been discriminated against may file a complaint no later than 30 days after the discrimination occurred with the Environment Department, Occupational Health and Safety Bureau at the address shown above.

Notice to Employees - The law gives an employee or his/her representative the opportunity to object to any abatement date set for a violation if he/she believes the date to be unreasonable. The contest must be mailed to the Environment Department, Occupational Health and Safety Bureau at the address shown above and postmarked within 15 working days (excluding weekends and Federal holidays) of the receipt by the employer of this Citation and Notification of Penalty.

Environment Department Occupational Health and Safety Bureau



525 Camino de los Marquez, Suite 3 UNKNOWN

Santa Fe, NM 87505

Phone: (505) 476-8700 Fax: (505) 476-8734

Inspection 1687441

Number:

Inspection Date(s): 07/31/2023-07/31/2023

Issuance Date: 01/29/2024

Citation and Notification of Penalty

Company Name: Hellbent Construction, LLC. **Inspection Site:** 4 Dovela Ct. Santa Fe, NM 87508

<u>Citation 1 Item 1 a</u> Type of Violation: **Serious**

11.5.3.9 NMAC

29 CFR 1926.451(b)(1)(i): Each platform unit (e.g., scaffold plank, fabricated plank, fabricated deck, or fabricated platform) shall be installed so that the space between adjacent units and the space between the platform and the uprights is no more than 1 inch (2.5 cm) wide, except where the employer can demonstrate that a wider space is necessary (for example, to fit around uprights when side brackets are used to extend the width of the platform).

On or about July 31, 2023 Hellbent Construction employees were working on a scaffold that was not fully planked and decked exposing employees to fall hazards.

PROOF OF ABATEMENT:

Date Corrected:		
Describe Corrective Action:		

Date By Which Violation Must be Abated: Proposed Penalty:

February 23, 2024 \$2,500.00

Environment Department Occupational Health and Safety Bureau



525 Camino de los Marquez, Suite 3 UNKNOWN Santa Fe, NM 87505

Salita Fe, INVI 6/303

Phone: (505) 476-8700 Fax: (505) 476-8734

Inspection 1687441

Number:

Inspection Date(s): 07/31/2023-07/31/2023

Issuance Date: 01/29/2024

Citation and Notification of Penalty

Company Name: Hellbent Construction, LLC. **Inspection Site:** 4 Dovela Ct. Santa Fe, NM 87508

<u>Citation 1 Item 1 b</u> Type of Violation: **Serious**

11.5.3.9 NMAC

29 CFR 1926.451(c)(2): Supported scaffold poles, legs, posts, frames, and uprights shall bear on base plates and mud sills or other adequate firm foundation.

On or about July 31, 2023, employees of Hellbent Construction were working with scaffolds that did not have base plates and mud sills or other adequate firm foundation, exposing themselves to unstable scaffolds and fall hazards.

PROOF OF ABATEMENT:

Date Corrected:	
Describe Corrective Action:	

Date By Which Violation Must be Abated: February 23, 2024
Proposed Penalty: \$0.00

Environment Department Occupational Health and Safety Bureau



525 Camino de los Marquez, Suite 3 UNKNOWN Santa Fe, NM 87505

Phone: (505) 476-8700 Fax: (505) 476-8734

Inspection 1687441

Number:

Inspection Date(s): 07/31/2023-07/31/2023

Issuance Date: 01/29/2024

Citation and Notification of Penalty

Company Name: Hellbent Construction, LLC. **Inspection Site:** 4 Dovela Ct. Santa Fe, NM 87508

<u>Citation 1 Item 1 c</u> Type of Violation: **Serious**

11.5.3.9 NMAC

29 CFR 1926.451(e)(1): When scaffold platforms are more than 2 feet (0.6 m) above or below a point of access, portable ladders, hook-on ladders, attachable ladders, stair towers (scaffold stairways/towers), stairway-type ladders (such as ladder stands), ramps, walkways, integral prefabricated scaffold access, or direct access from another scaffold, structure, personnel hoist, or similar surface shall be used. Cross-braces shall not be used as a means of access.

On or about July 31, 2023, employees of Hellbent Construction were using the scaffold cross-braces as a ladder to exit the roof, exposing themselves to fall hazards.

PROOF OF ABATEMENT:

Date Corrected:	
Describe Corrective Action:	

Date By Which Violation Must be Abated: Proposed Penalty:

February 23, 2024 \$0.00

Environment Department Occupational Health and Safety Bureau



525 Camino de los Marquez, Suite 3 **UNKNOWN** Santa Fe, NM 87505

Phone: (505) 476-8700 Fax: (505) 476-8734

Inspection 1687441

Number:

Inspection Date(s): 07/31/2023-07/31/2023

Issuance Date: 01/29/2024

Citation and Notification of Penalty

Company Name: Hellbent Construction, LLC. Inspection Site: 4 Dovela Ct. Santa Fe, NM 87508

Citation 1 Item 2 Type of Violation: Serious

11.5.3.9 NMAC

29 CFR 1926.454(a): The employer shall have each employee who performs work while on a scaffold trained by a person qualified in the subject matter to recognize the hazards associated with the type of scaffold being used and to understand the procedures to control or minimize those hazards.

On or about July 31, 2023, Hellbent Construction did not have a qualified person on staff to train and minimize hazards to employees while working on scaffolds, exposing employees to fall hazards as they perform scaffolding work.

PROOF OF ABATEMENT:

Date Corrected:		
Describe Corrective Action:		

Date By Which Violation Must be Abated: Proposed Penalty:

February 23, 2024 \$2,500.00

Environment Department Occupational Health and Safety Bureau



525 Camino de los Marquez, Suite 3 UNKNOWN Santa Fe, NM 87505

Phone: (505) 476-8700 Fax: (505) 476-8734

Inspection 1687441

Number:

Inspection Date(s): 07/31/2023-07/31/2023

Issuance Date: 01/29/2024

Citation and Notification of Penalty

Company Name: Hellbent Construction, LLC. **Inspection Site:** 4 Dovela Ct. Santa Fe, NM 87508

<u>Citation 1 Item 3</u> Type of Violation: **Serious**

11.5.3.9 NMAC

29 CFR 1926.501(b)(13): "Residential construction." Each employee engaged in residential construction activities 6 feet (1.8 m) or more above lower levels shall be protected by guardrail systems, safety net system, or personal fall arrest system unless another provision in paragraph (b) of this section provides for an alternative fall protection measure. Exception: When the employer can demonstrate that it is infeasible or creates a greater hazard to use these systems, the employer shall develop and implement a fall protection plan which meets the requirements of paragraph (k) of 1926.502.

Note: There is a presumption that it is feasible and will not create a greater hazard to implement at least one of the above-listed fall protection systems. Accordingly, the employer has the burden of establishing that it is appropriate to implement a fall protection plan which complies with 1926.502(k) for a particular workplace situation, in lieu of implementing any of those systems.

On or about July 31, 2023, Hellbent Construction employees were not provided fall protection while working at heights of 6 feet or greater on a roof of a residential home, exposing employees to fall hazards.

PROOF OF ABATEMENT:

Date Corrected:		
Describe Corrective Action:		

Date By Which Violation Must be Abated: Proposed Penalty:

February 23, 2024 \$3,109.00

Environment Department Occupational Health and Safety Bureau



525 Camino de los Marquez, Suite 3 UNKNOWN

Santa Fe, NM 87505

Phone: (505) 476-8700 Fax: (505) 476-8734

Inspection 1687441

Number:

Inspection Date(s): 07/31/2023-07/31/2023

Issuance Date: 01/29/2024

Citation and Notification of Penalty

Company Name: Hellbent Construction, LLC. **Inspection Site:** 4 Dovela Ct. Santa Fe, NM 87508

<u>Citation 1 Item 4</u> Type of Violation: **Serious**

11.5.3.9 NMAC

29 CFR 1926.503(a)(1): The employer shall provide a training program for each employee who might be exposed to fall hazards. The program shall enable each employee to recognize the hazards of falling and shall train each employee in the procedures to be followed in order to minimize these hazards.

On or about July 31, 2023, Hellbent Construction did not provide training to employees who might be expose and recognize fall hazards.

PROOF OF ABATEMENT:

Date Corrected:	
Describe Corrective Action:	

Date By Which Violation Must be Abated: Proposed Penalty:

February 23, 2024 \$2,500.00

Environment Department Occupational Health and Safety Bureau



525 Camino de los Marquez, Suite 3 UNKNOWN Santa Fe, NM 87505

Phone: (505) 476-8700 Fax: (505) 476-8734

Inspection 1687441

Number:

Inspection Date(s): 07/31/2023-07/31/2023

Issuance Date: 01/29/2024

Citation and Notification of Penalty Company Name: Hellbent Construction, LLC. Inspection Site: 4 Dovela Ct. Santa Fe, NM 87508	
I attest that all corrective actions contained in this document are accura the abatement.	te and affected employees have been informed of
Signature	Date

Gregory J. Marquez
Program Manager

Environment Department Occupational Health and Safety Bureau 525 Camino de los Marquez, Suite 3

Santa Fe NM 87505

Phone: (505) 476-8700 Fax: (505) 476-8734



INVOICE

Company Name: Hellbent Construction, LL	C.
Inspection Site: 4 Dovela Ct. Santa Fe, NM	87508

Issuance Date: 01/29/2024

Summary of Penalties for Inspection Number: 1687441

Citation 1 Item 1a, Serious	\$2,500.00
Citation 1 Item 1b, Serious	\$0.00
Citation 1 Item 1c, Serious	\$0.00
Citation 1 Item 2, Serious	\$2,500.00
Citation 1 Item 3, Serious	\$3,109.00
Citation 1 Item 4, Serious	\$2,500.00

TOTAL PROPOSED PENALTIES:

\$10,609.00

Please remit payment promptly to this office for the total amount of the uncontested penalties summarized above. Make your check or money order payable to: Environment Department, Occupational Health and Safety Bureau. Please indicate OHSB's Inspection Number (indicated above) on the remittance.

OHSB does not agree to any restrictions or conditions or endorsements put on any check or money order for less than full amount due, and will cash the check or money order as if these restrictions, conditions, or endorsements do not exist.

Gregory J. Marquez, Program Manager	Date