



MICHELLE LUJAN GRISHAM
GOVERNOR

JAMES C. KENNEY
CABINET SECRETARY

CERTIFIED MAIL – RETURN RECEIPT REQUESTED

September 9, 2022

Jose Terrones, Superintendent
Anthony Wastewater and Sanitation District
P.O. Box 1751
Anthony, New Mexico 88021

RE: Draft Discharge Permit Renewal and Modification, DP-450, Anthony Wastewater Treatment Facility

Dear Jose Terrones:

The New Mexico Environment Department (NMED) hereby provides notice to Anthony Wastewater and Sanitation District of the proposed approval of Ground Water Discharge Permit Renewal and Modification, DP-450, (copy enclosed), pursuant to Subsection H of 20.6.2.3108 NMAC. NMED will publish notice of the availability of the draft Discharge Permit in the near future for public review and comment and will forward a copy of that notice to you.

Prior to making a final ruling on the proposed Discharge Permit, NMED will allow 30 days from the date the public notice is published in the newspaper for any interested party, including the Discharge Permit applicant, i.e., yourself, to submit written comments and/or a request a public hearing. A hearing request shall set forth the reasons why a hearing is requested. NMED will hold a hearing in response to a timely hearing request if the NMED Secretary determines there is substantial public interest in the proposed Discharge Permit.

Please review the enclosed draft Discharge Permit carefully. Please be aware that this Discharge Permit may contain conditions that require the permittee to implement operational, monitoring or closure actions by a specified deadline.

Please submit written comments or a request for hearing to my attention at the address above or via email to aracely.tellez@state.nm.us. If NMED does not receive written comments or a request for hearing during the public comment period, the draft Discharge Permit will become final.

Thank you for your cooperation during the review process. Feel free to contact me with any questions at (505) 629-8864.

SCIENCE | INNOVATION | COLLABORATION | COMPLIANCE

Ground Water Quality Bureau | 1190 Saint Francis Drive, PO Box 5469, Santa Fe, New Mexico 87502-5469

Telephone (505) 827-2900 | www.env.nm.gov/gwqb/

Jose Terrones

DATE

Page 2 of 2

Sincerely,

Aracely Tellez

Environmental Scientist

Encl: Draft Discharge Permit Renewal and Modification, DP-450

cc: Jane DeRose-Bamman, DeRose-Bamman Consulting LLC, derosebammanconsulting@gmail.com
Ryan Lunderville, Facility Operator, rlunderville@awsd.us
Clayton Ten Eyck, P.E., Molzen-Corbin & Assoc. Inc., CtenEyck@molzencorbin.com



NEW MEXICO
ENVIRONMENT DEPARTMENT
Ground Water Quality Bureau
1190 Saint Francis Drive / PO Box 5469
Santa Fe, NM 87502-5469
Phone (505) 827-2900 Fax (505) 827-2965
www.env.nm.gov



Draft: September 9, 2022

GROUND WATER QUALITY BUREAU
DISCHARGE PERMIT
Issued under 20.6.2 NMAC

Facility Name: Anthony Wastewater Treatment Facility
Discharge Permit Number: DP-450
Facility Location: 1470 Fourth Street
Anthony, NM 88021

County: Doña Ana

Permittee: Anthony Water and Sanitation District
Mailing Address: P.O. Box 1751
Anthony, NM 88021

Facility Contact: Jose Terrones, Superintendent
Telephone Number/Email: 575-882-3922/ jterrones@awsd.us

Permitting Action: Renewal and Modification
Permit Issuance Date: DATE
Permit Expiration Date: DATE

NMED Permit Contact: Aracely Tellez
Telephone Number/Email: 505-629-8864 / Aracely.tellez@state.nm.us or
pps.general@state.nm.us

JUSTIN D. BALL
Chief, Ground Water Quality Bureau
New Mexico Environment Department

Date

TABLE OF CONTENTS

I.	INTRODUCTION	1
II.	FINDINGS	3
III.	AUTHORIZATION TO DISCHARGE	3
IV.	CONDITIONS	4
A.	OPERATIONAL PLAN.....	4
	Operating Conditions	Error! Bookmark not defined.
	Operational Actions with Implementation Deadlines	Error! Bookmark not defined.
	Operating Conditions	4
B.	MONITORING AND REPORTING	9
	Due Dates for Monitoring Reports	9
	Monitoring Actions with Implementation Deadlines	10
	Groundwater Monitoring Conditions	11
	Facility Monitoring Conditions	13
C.	CONTINGENCY PLAN	18
D.	CLOSURE PLAN	24
	Permanent Facility Closure Conditions	24
E.	GENERAL TERMS AND CONDITIONS	25

ATTACHMENTS

Discharge Permit Summary
New Mexico Environment Department Ground Water Quality Bureau Monitoring Well
Construction and Abandonment Guidelines, Revision 1.1, March 2011 (Monitoring
Well Guidance)

I. INTRODUCTION

The New Mexico Environment Department (NMED) issues this groundwater discharge permit Renewal and Modification (Discharge Permit or DP-450) to the Anthony Water and Sanitation District (Anthony W&SD or Permittee) pursuant to the New Mexico Water Quality Act (WQA), NMSA 1978 §§74-6-1 through 74-6-17, and the New Mexico Water Quality Control Commission (WQCC) Ground and Surface Water Protection Regulations, 20.6.2 NMAC.

NMED's purpose in issuing this Discharge Permit, and in imposing the requirements and conditions specified herein, is to control the discharge of water contaminants from the Anthony Wastewater Treatment Facility (WWTF or Facility) in order to protect groundwater and those segments of surface water gaining from groundwater inflow for present and potential future use as domestic and agricultural water supply and other uses, and to protect public health. It is NMED's determination in issuing this Discharge Permit that the Permittee has met the requirements of Subsection C of 20.6.2.3109 NMAC. The Permittee is responsible for complying with the terms and conditions of this Discharge Permit pursuant to Section 20.6.2.3104 NMAC; failure to do so may result in enforcement action by NMED (20.6.2.1220 NMAC).

Described below are the activities that produce the discharge, the location of the discharge, and the quantity, quality and flow characteristics.

The WWTF receives and treats domestic wastewater at a volume of up to 1.3 million gallons per day (MGD). Domestic wastewater is received and treated using an extended aeration/anoxic treatment plant including storage impoundments, followed by UV disinfection. The Permittee dewater sludge removed from the plant by a belt press or in drying beds and removes the dried sludge from the site to a landfill under an approved Solid Waste Disposal Plan. Treated wastewater (reclaimed wastewater) is discharged to irrigate the Facility grounds, for plant process and wash water at the Facility, may be transferred to other entities separately permitted by NMED, for temporary uses that do not require a Discharge Permit, or is discharged to the Rio Grande River under a separately issued National Pollutant Discharge Elimination System (NPDES) Permit (Permit Number NM0029629).

The Discharge Permit modification consists of an increase in the maximum daily discharge volume from 980,000 gallons per day to 1.3 MGD.

The discharge may contain water contaminants or toxic pollutants elevated above the standards of Section 20.6.2.3103 NMAC and is not subject to the exemption at Subsection 20.6.2.3105.A NMAC.

Data collected from an on-site monitoring well(s) document groundwater contamination attributed to one or more sources at this Facility. The on-site monitoring well has exceedances of groundwater quality standards for Total Nitrogen according to the criteria of Sections

20.6.2.3101 and 20.6.2.3103 NMAC. This Discharge Permit contains requirements, actions and contingencies intended to address the source(s) of documented groundwater contamination.

The Facility is located at 1470 Fourth Street, in Anthony, in Section 26, Township 26S, Range 03E, in Doña Ana County. A discharge at the Facility is most likely to affect groundwater at a depth of approximately 55 feet and having a pre-discharge total dissolved solids (TDS) concentration of approximately 1,680 milligrams per liter.

NMED issued the original Discharge Permit to the Permittee on January 9, 1987, and subsequently renewed or modified the Permit on September 23, 1992, July 20, 1998, March 29, 2004, October 18, 2013 and August 1, 2019. The application (i.e., discharge plan) associated with this Discharge Permit consists of the materials submitted by the Permittee dated August 18, 2021, and materials contained in the administrative record prior to issuance of this Discharge Permit.

The Permittee shall manage the discharge in accordance with all conditions and requirements of this Discharge Permit.

NMED reserves the right to require a Discharge Permit modification in the event NMED determines that the Permittee is or may be violating, or is likely to violate in the future, the requirements of 20.6.2 NMAC or the standards of Section 20.6.2.3103 NMAC. NMED reserves this right pursuant to Section 20.6.2.3109 NMAC. An NMED requirement to modify the Discharge Permit may result from a determination by the department that structural controls and/or management practices approved under this Discharge Permit are insufficiently protective of groundwater quality and human health. NMED reserves the right to require the Permittee implement abatement of water pollution and remediate groundwater quality.

NMED issuance of this Discharge Permit does not relieve the Permittee of the responsibility to comply with the WQA, WQCC Regulations, and any other applicable federal, state and/or local laws and regulations, such as zoning requirements and nuisance ordinances.

This Discharge Permit may use the following acronyms and abbreviations.

Abbreviation	Explanation	Abbreviation	Explanation
BOD ₅	biochemical oxygen demand (5-day)	NMED	New Mexico Environment Department
CAP	Corrective Action Plan	NMSA	New Mexico Statutes Annotated
CFR	Code of Federal Regulations	NO ₃ -N	nitrate-nitrogen
CFU	colony forming unit	NTU	nephelometric turbidity units
Cl	chloride	QA/QC	Quality Assurance/Quality Control

Abbreviation	Explanation		Abbreviation	Explanation
EPA	United States Environmental Protection Agency		TDS	total dissolved solids
Gpd	gallons per day		TKN	total Kjeldahl nitrogen
LAA	land application area		total nitrogen	= TKN + NO ₃ -N
LADS	Land Application Data Sheet(s)		TRC	total residual chlorine
mg/L	milligrams per liter		TSS	total suspended solids
mL	milliliters		WQA	New Mexico Water Quality Act
MPN	most probable number		WQCC	Water Quality Control Commission
NMAC	New Mexico Administrative Code		WWTF	Wastewater Treatment Facility

II. FINDINGS

In issuing this Discharge Permit, NMED finds the following.

1. The Permittee is discharging effluent or leachate from the Facility so that such effluent or leachate may move into groundwater of the State of New Mexico that has an existing concentration of 10,000 mg/L or less of TDS, within the meaning of Subsection A of 20.6.2.3101 NMAC, without exceeding standards of 20.6.2.3103 NMAC for any water contaminant.
2. The Permittee is discharging effluent or leachate from the Facility directly or indirectly into groundwater pursuant to this Discharge Permit and Sections 20.6.2.3000 through 20.6.2.3114 NMAC.
3. The discharge from the Facility is not subject to any of the exemptions of Section 20.6.2.3105 NMAC.

III. AUTHORIZATION TO DISCHARGE

The Permittee is responsible for ensuring that discharges authorized by this Discharge Permit are consistent with the terms and conditions herein pursuant to 20.6.2.3104 NMAC.

This Discharge Permit authorizes the Permittee to receive and treat up to 1.3 MGD of domestic wastewater using an extended aeration/anoxic treatment plant followed by UV disinfection pursuant to NPDES NM0029629. The Permittee dewateres sludge removed from the plant and processed it by a belt press or in drying beds and removes the dried sludge from the site to an approved landfill. This Discharge Permit authorizes the Permittee to store treated wastewater (reclaimed wastewater) in two synthetically lined impoundments for the following purposes: drip or flood irrigation of Facility grounds and for plant process and wash water at the Facility. This

Discharge Permit also authorizes the Permittee to transfer reclaimed wastewater from the former chlorine contact chamber to separately permitted entities and for temporary uses (dust control, construction uses) that NMED has determined do not require a Discharge Permit.

[20.6.2.3104 NMAC, Subsection C of 20.6.2.3106 NMAC, Subsection D of 20.6.2.3109 NMAC]

IV. CONDITIONS

NMED issues this Discharge Permit for the discharge of water contaminants subject to the following conditions.

A. OPERATIONAL PLAN

#	Terms and Conditions
1.	The Permittee shall implement the following operational plan to ensure compliance with Title 20, Chapter 6, Parts 2 and 4 NMAC. [Subsection C of 20.6.2.3109 NMAC]
2.	The Permittee shall operate in a manner that does not violate standards and requirements of Sections 20.6.2.3101 and 20.6.2.3103 NMAC. [20.6.2.3101 NMAC, 20.6.2.3103 NMAC, Subsection C of 20.6.2.3109 NMAC]

Operating Conditions

#	Terms and Conditions									
3.	<p>The Permittee shall ensure that reclaimed wastewater discharged from UV disinfection does not exceed the following discharge limit.</p> <p>Total Nitrogen: 20 mg/L</p> <p>[Subsection C of 20.6.2.3109 NMAC]</p>									
4.	<p>The Permittee shall ensure that Class 1B reclaimed domestic wastewater discharged from UV disinfection does not exceed the following discharge limits.</p> <table><tr><td><u>Test</u></td><td><u>30-day Average</u></td><td><u>Maximum</u></td></tr><tr><td>Fecal coliform</td><td>100 CFU or MPN/100 mL</td><td>200 CFU or MPN/100 mL</td></tr><tr><td>OR</td><td>OR</td><td>OR</td></tr></table>	<u>Test</u>	<u>30-day Average</u>	<u>Maximum</u>	Fecal coliform	100 CFU or MPN/100 mL	200 CFU or MPN/100 mL	OR	OR	OR
<u>Test</u>	<u>30-day Average</u>	<u>Maximum</u>								
Fecal coliform	100 CFU or MPN/100 mL	200 CFU or MPN/100 mL								
OR	OR	OR								

#	Terms and Conditions														
		<table><tr><td>E. coli bacteria</td><td>63 CFU or MPN/100mL</td><td>126 CFU or MPN/100 mL</td></tr><tr><td>BOD₅</td><td>30 mg/L</td><td>45 mg/L</td></tr><tr><td>TSS OR Turbidity</td><td>30 mg/L</td><td>45 mg/L</td></tr><tr><td>UV Transmissivity</td><td>Monitor Only</td><td>Monitor Only</td></tr></table>	E. coli bacteria	63 CFU or MPN/100mL	126 CFU or MPN/100 mL	BOD ₅	30 mg/L	45 mg/L	TSS OR Turbidity	30 mg/L	45 mg/L	UV Transmissivity	Monitor Only	Monitor Only	
E. coli bacteria	63 CFU or MPN/100mL	126 CFU or MPN/100 mL													
BOD ₅	30 mg/L	45 mg/L													
TSS OR Turbidity	30 mg/L	45 mg/L													
UV Transmissivity	Monitor Only	Monitor Only													
	[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]														
5.	<p>The Permittee shall apply reclaimed domestic wastewater to the Anthony W&SD owned re-use areas such that the amount of total nitrogen applied does not exceed 200 pounds per acre in any 12-month period. The Permittee shall not adjust nitrogen content to account for volatilization or mineralization processes. The Permittee shall prevent excessive ponding from occurring due to the discharge.</p> <p>[Subsection C of 20.6.2.3109 NMAC]</p>														
6.	<p>The Permittee shall ensure adherence to the following general requirements for above-ground use of reclaimed domestic wastewater.</p> <p>a) The Permittee shall install and maintain signs in English and Spanish at all reuse areas such that they are visible and legible for the term of this Discharge Permit. The Permittee shall post signs at the entrance to reuse areas and at other locations where public exposure to reclaimed domestic wastewater may occur. The signs shall state: NOTICE: THIS AREA IS IRRIGATED WITH RECLAIMED WASTEWATER - DO NOT DRINK. AVISO: ESTA ÁREA ESTÁ REGADA CON AGUAS NEGRAS RECOBRADAS - NO TOMAR. The Permittee may submit alternate wording and/or graphics to NMED for approval.</p> <p>b) Reclaimed domestic wastewater systems shall have no direct or indirect cross connections with public water systems or irrigation wells pursuant to the latest revision of the New Mexico Plumbing Code (14.8.2 NMAC) and New Mexico Mechanical Code (14.9.2 NMAC).</p> <p>c) Above-ground use of reclaimed domestic wastewater shall not result in excessive ponding of wastewater and shall not exceed the water consumptive needs of the crop. The Permittee shall not discharge reclaimed domestic wastewater at times when the reuse area is saturated or frozen.</p> <p>d) The Permittee shall confine discharge of reclaimed domestic wastewater to the reuse area.</p> <p>e) The Permittee shall not discharge reclaimed domestic wastewater to crops used for human consumption.</p> <p>f) Water supply wells within 200 feet of a reuse area shall have adequate wellhead construction pursuant to 19.27.4 NMAC.</p>														

#	Terms and Conditions
	<p>g) Existing and accessible portions of the reclaimed domestic wastewater distribution system (with the exception of application equipment such as sprinklers or pivots) shall be colored purple or clearly labeled as being part of a reclaimed domestic wastewater distribution system. Piping, valves, outlets, and other plumbing fixtures shall be purple pursuant to the latest revision of the New Mexico Plumbing Code (14.8.2 NMAC) and New Mexico Mechanical Code (14.9.2 NMAC) to differentiate piping or fixtures used to convey reclaimed wastewater from those intended for potable or other uses.</p> <p>h) Valves, outlets, and sprinkler heads used in reclaimed wastewater systems shall be accessible only to authorized personnel.</p> <p>The Permittee shall demonstrate adherence to these requirements by submitting documentation consisting of narrative statements and date-stamped photographs as appropriate. The Permittee shall submit the documentation to NMED once during the term of this Discharge Permit in the next required periodic monitoring report after the issuance of the Discharge Permit.</p> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1–78, § 74-6–5.D]</p>
7.	<p>The Permittee shall manage the flood and drip irrigation of Class 1B reclaimed domestic wastewater on Anthony W&SD property in a manner that minimizes public contact.</p> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1–78, § 74-6-5.D]</p>
8.	<p>The Permittee shall institute a backflow prevention method to protect wells and public water supply systems from contamination by reclaimed domestic wastewater prior to discharging to the reuse area. Backflow prevention shall be achieved by a total disconnect (physical air gap separation between the discharge pipe and the liquid surface at least twice the diameter of the discharge pipe), or by a reduced pressure principal backflow prevention assembly (RP) installed on the line between the fresh water supply wells or public water supply and the reclaimed domestic wastewater delivery system. The Permittee shall maintain backflow prevention at all times.</p> <p>The Permittee shall have RP devices inspected and tested by a certified backflow prevention assembly tester at the time of installation, repair or relocation and at least on an annual basis thereafter. The backflow prevention assembly tester shall have successfully completed a 40-hour backflow prevention course based on the University of Southern California’s Backflow Prevention Standards and Test Procedures, and obtained certification demonstrating completion. The Permittee shall have all malfunctioning RP devices repaired or replaced within 30 days of discovery. The Permittee shall cease using supply lines associated with the RP device until repair or replacement is complete.</p>

#	Terms and Conditions
	<p>The Permittee shall maintain copies of the inspection and maintenance records and test results for each RP device associated with the backflow prevention program at a location available for inspection by NMED.</p> <p>[Subsection C of 20.6.2.3109 NMAC]</p>
9.	<p>The Permittee shall meet the following requirements for the temporary above-ground use of reclaimed domestic wastewater.</p> <ul style="list-style-type: none">a) Restrict access to the reclaimed domestic wastewater distribution system (standpipe). Transfer of reclaimed domestic wastewater to other users shall only be done by the Permittee or its designee. The Permittee shall prohibit public access to the reclaimed domestic wastewater system.b) Notify all recipients of reclaimed domestic wastewater for temporary uses in writing of the following.<ul style="list-style-type: none">i. Reclaimed domestic wastewater is approved only for construction activities; soil compaction; mixing of mortars, slurries or cement; dust control on roads and construction sites; animal watering; and irrigation of non-food crops.ii. Reclaimed domestic wastewater shall be discharged by gravity flow or under low pressure in a manner that minimizes misting and does not results in excessive standing or ponding of wastewater.iii. If the discharge method results in misting, the area(s) receiving the reclaimed domestic wastewater must be 100 feet from areas accessible to the public.iv. The area receiving the discharge must be 300 feet from potable water supply wells.v. Transport vehicles and storage tanks containing reclaimed domestic wastewater shall have signs, in English and Spanish, identifying the contents as non-potable water and advising against consumption.vi. The user shall not apply of reclaimed domestic wastewater at times when the receiving area is saturated or frozen. <p>The Permittee shall maintain a log of all recipients of reclaimed domestic wastewater and shall provide the log to NMED upon request.</p> <p>[20.6.2.3109 NMAC]</p>
10.	<p>The Permittee shall not transfer reclaimed wastewater to other entities until they have obtained separate groundwater discharge permits from NMED, unless otherwise authorized in this Discharge Permit.</p> <p>[20.6.2.3109 NMAC]</p>

#	Terms and Conditions
11.	<p>The Permittee shall notify NMED prior to commencing transfer of reclaimed wastewater to other, separately permitted entities for the first time.</p> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978 74-6-5.D]</p>
12.	<p>The Permittee shall maintain fences around the Facility to restrict access by the general public and animals. The fences shall consist of a minimum of six-foot chain link or field fencing and locking gates. The Permittee shall maintain the fences to serve the stated purpose throughout the term of this Discharge Permit.</p> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p>
13.	<p>The Permittee shall maintain signs indicating that the wastewater at the Facility is not potable. The Permittee shall post signs at the Facility entrance and other areas where there is potential for public contact with wastewater. The Permittee shall print signs in English and Spanish and shall ensure the signs remain visible and legible for the term of this Discharge Permit.</p> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p>
14.	<p>The Permittee shall maintain the paved drying beds to avoid conditions that could affect the structural integrity of the paved drying beds. Characterization of such conditions may include the following:</p> <ul style="list-style-type: none">• erosion damage;• animal burrows or other damage;• the presence of vegetation including aquatic plants, weeds, woody shrubs or trees growing within five feet of the top inside edge of a sub-grade paved drying bed, within five feet of the toe of the outside berm of an above-grade portion of a paved drying bed, or within the paved drying bed itself;• the presence of large debris or large quantities of debris in the paved drying bed;• evidence of seepage; or• evidence of berm subsidence. <p>The Permittee shall control vegetation growing around the paved drying beds by mechanical removal that is protective of the paved drying beds.</p> <p>The Permittee shall visually inspect the paved drying beds and surrounding berms on a monthly basis to ensure proper maintenance. In the event that inspection reveals any evidence of damage that threatens the structural integrity of the paved drying beds, or that may result in an unauthorized discharge, the Permittee shall implement the Contingency Plan set forth in this Discharge Permit.</p>

#	Terms and Conditions
	<p>The Permittee shall create and maintain a log of all paved drying bed inspections which describes the date of the inspection, any findings and repairs and the name of the person responsible for the inspection. The Permittee shall provide the log to NMED upon request.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
15.	<p>The Permittee shall properly manage all solids generated by the treatment system to maintain effective operation of the system by removing solids as necessary and in accordance with associated equipment manufacturer's specifications. The Permittee shall contain, transport and dispose of solids removed from the treatment process in accordance with all local, state, and federal regulations.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
16.	<p>The Permittee shall utilize operators, certified by the State of New Mexico at the appropriate level pursuant to 20.7.4 NMAC, to operate the wastewater collection, treatment and disposal systems. A certified operator or a direct supervisee of a certified operator shall perform the operations and maintenance of all or any part of the wastewater system.</p> <p>The Permittee shall notify the NMED within 24 hours if at any time the Permittee no longer has a certified operator maintaining the system.</p> <p>[Subsection C of 20.6.2.3109 NMAC, 20.7.4 NMAC]</p>

B. MONITORING AND REPORTING

#	Terms and Conditions
17.	<p>The Permittee shall conduct the monitoring, reporting, and other requirements listed below in accordance with the monitoring requirements of this Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
18.	<p>METHODOLOGY – Unless otherwise specified by this Discharge Permit, or approved in writing by NMED, the Permittee shall use sampling and analytical techniques that conform with the references listed in Subsection B of 20.6.2.3107 NMAC.</p> <p>[Subsection B of 20.6.2.3107 NMAC]</p>

Due Dates for Monitoring Reports

#	Terms and Conditions
19.	<p>Quarterly monitoring - The Permittee shall perform monitoring and other Permit required actions during the following periods and shall submit quarterly reports to NMED by the following due dates:</p> <ul style="list-style-type: none">• January 1st through March 31st – due by May 1st;• April 1st through June 30th – due by August 1st;• July 1st through September 30th – due by November 1st; and• October 1st through December 31st – due by February 1st. <p>[Subsection A of 20.6.2.3107 NMAC]</p>

Monitoring Actions with Implementation Deadlines

#	Terms and Conditions
20.	<p>The Permittee shall sample reclaimed domestic wastewater for the presence of perfluorinated chemicals (PFCs).</p> <p>Within 2.5 years of the issuance date of this Discharge Permit (by DATE), the Permittee shall collect a single grab sample UV disinfection. The Permittee shall analyze the sample for the following PFCs:</p> <ul style="list-style-type: none">• perfluorohexane sulfonic acid (PFHxS) (CAS 355-46-4)• perfluorooctane sulfonate (PFOS) (CAS 1763-23-1)• perfluorooctanoic acid (PFOA) (CAS 335-67-1) <p>The Permittee shall properly collect, prepare, preserve, transport, and analyze the sample in accordance with ASTM D7979-17, or an equivalent method that uses liquid chromatography and tandem mass spectrometry (LC/MS/MS). The reporting limit shall be low enough to identify whether the combined concentration of the perfluorinated chemicals is less than the Tap Water Screening Level identified in the <i>NMED Risk Assessment Guidance for Site Assessments and Investigations</i>, Table A-1 available on the NMED Hazardous Waste Bureau's website under Guidance Documents. The Permittee shall take appropriate measures to avoid cross contamination while collecting and transporting the sample. The selected laboratory should be able to provide guidance that ensures sample integrity. The Permittee shall submit a copy of the laboratory report, including analytical results, the QA/QC summary, and the Chain of Custody to NMED within 30 days of laboratory report receipt.</p> <p>[Subsection H of 20.6.2.3109 NMAC, Subsection A of 20.6.2.3107 NMAC]</p>

#	Terms and Conditions
21.	<p>Within 90 days following the issuance date of this Discharge Permit (by DATE), the Permittee shall install the following flow meter:</p> <ul style="list-style-type: none">One totalizing flow meter installed on the facility's reclaimed wastewater to measure the volume of reclaimed wastewater discharged for irrigation of District owned property. <p>Confirmation of meter installation, type calibration and locations shall be submitted to NMED within 30 days of completed installations.</p> <p>[Subsections A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
22.	<p>Prior to transferring wastewater to other entities, the permittee shall install the following flow meters:</p> <ul style="list-style-type: none">One totalizing flow meter installed on the facility's reclaimed wastewater chlorine contact chamber to measure the volume of reclaimed water discharge for temporary uses that do not require a Discharge Permit.One totalizing flow meter installed on the facility's reclaimed wastewater transfer system to measure the volume for reuse sent to each of the other separately permitted entities. <p>Confirmation of meter installation, type, calibration and locations shall be submitted to NMED within 30 days of completed installations.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>

Groundwater Monitoring Conditions

#	Terms and Conditions
23.	<p>The Permittee shall perform quarterly groundwater sampling in the following groundwater monitoring wells and analyze the samples for TKN, NO₃-N, TDS and Cl.</p> <ul style="list-style-type: none">a) MW-1, located hydrologically upgradient of the Facility at 32.022520, -106.59865b) MW-2, located hydrologically downgradient of the Facility at 32.02156, -106.59979c) MW-3a, located at an alternate location from MW-2 and hydrologically downgradient of the UV disinfection unit and approximately 210 feet west of the northwest corner of the blower building.

#	Terms and Conditions
	<p>The Permittee shall perform groundwater sample collection, preservation, transport and analysis according to the following procedures.</p> <ul style="list-style-type: none">a) Measure the depth-to-most-shallow groundwater from the top of the well casing to the nearest one-hundredth of a foot.b) Purge three well volumes of water from the well prior to sample collection.c) Obtain samples from the well for analysis.d) Properly prepare, preserve and transport samples.e) Analyze samples in accordance with the methods authorized in this Discharge Permit. <p>The Permittee shall submit the depth-to-most-shallow groundwater measurements and the laboratory analytical data results including the laboratory QA/QC summary report for each well, and a Facility layout map showing the location and number of each well to NMED in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
24.	<p>The Permittee shall develop a groundwater elevation contour map, i.e., potentiometric surface map, on a quarterly basis using the top of casing elevation data from the monitoring well survey and the most recent depth-to-most-shallow groundwater measurements, referenced to mean sea level, obtained during the groundwater sampling required by this Discharge Permit.</p> <p>The groundwater elevation contour map shall depict the groundwater flow direction based on the groundwater elevation contours. The Permittee shall estimate groundwater elevations between monitoring well locations using common interpolation methods. The Permittee shall use a contour interval appropriate to the data but shall not be greater than two feet. Groundwater elevation contour maps shall use arrows to depict the groundwater flow direction based on the orientation of the groundwater elevation contours and shall locate and identify each monitoring well and contaminant source.</p> <p>The Permittee shall submit to NMED a groundwater elevation contour map in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
25.	<p>NMED shall have the option to perform downhole inspections of all groundwater monitoring wells identified in this Discharge Permit. NMED shall establish the inspection date and notify the Permittee. The Permittee shall remove any existing dedicated pumps at least 48 hours prior to NMED inspection to allow adequate settling time of sediment agitated from pump removal.</p>

#	Terms and Conditions
	<p>Should the Permittee decide to install a pump in a monitoring well without a dedicated pump, the Permittee shall notify NMED at least 90 days prior to pump installation so that NMED can schedule a downhole well inspection(s) prior to pump placement.</p> <p>[Subsections A and D of 20.6.2.3107 NMAC]</p>

Facility Monitoring Conditions

#	Terms and Conditions
26.	<p>The Permittee shall measure the total monthly volume, calculate the daily average volume, and record the daily peak volume of wastewater received by the treatment facility each month using a Parshall flume equipped with head sensing, totalizing and chart recording/data logging mechanisms located at the influent line to the treatment plant. The Permittee shall submit the totalized average daily and peak daily influent volumes for each month to NMED in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
27.	<p>The Permittee shall on a monthly basis measure the volume discharged to <i>each</i> reuse location including the onsite irrigation system using a totalizing flow meter. The meter shall be located on the transfer line between the wastewater system and the individual reuse location.</p> <p>The Permittee shall maintain a log that records the date that discharges occur to <i>each</i> reuse location and the monthly totalizing meter readings and units of measurement. The Permittee shall use the log to calculate the total monthly volume of reclaimed domestic wastewater discharged to <i>each</i> location. The Permittee shall submit a copy of the log to NMED in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
28.	<p>All flow meters shall be capable of having their accuracy verified under working (i.e., real-time in-the-field) conditions. The Permittee shall develop a field verification method for each flow meter and shall utilize that method to check the accuracy of each respective meter. The Permittee shall perform field calibrations, at a minimum, on an annual basis. The Permittee shall also perform field calibrations upon repair or replacement of a flow measurement device.</p> <p>The Permittee shall calibrate each flow meter to its manufacturer's recommended specification which shall be no less accurate than plus or minus 10 percent of actual flow,</p>

#	Terms and Conditions
	<p>as measured under field conditions. An individual knowledgeable in flow measurement shall perform field calibration and the installation/operation of the device in use. The Permittee shall prepare a flow meter calibration report for each flow measurement device calibration event. The flow meter calibration report shall include the following information.</p> <ol style="list-style-type: none"> The location and meter identification. The method of flow meter field calibration employed. The measured accuracy of each flow meter prior to adjustment indicating the positive or negative offset as a percentage of actual flow as determined by an in-field calibration check. The measured accuracy of each flow meter following adjustment, if necessary, indicating the positive or negative offset as a percentage of actual flow of the meter. Any flow meter repairs made during the previous year or during field calibration. The name of the individual performing the calibration and the date of the calibration. <p>The Permittee shall maintain records of flow meter calibration(s) at a location accessible for review by NMED during Facility inspections.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
29.	<p>The Permittee shall visually inspect flow meters on a monthly basis for evidence of malfunction. The Permittee shall maintain a log of the inspections that includes a date of the inspection, findings and repairs, and the name of the inspector. The Permittee shall make the log available to NMED upon request.</p> <p>If a visual inspection indicates a flow meter is not functioning as required by this Discharge Permit, the Permittee shall repair or replace the meter within 30 days of discovery. For <i>repaired</i> meters, the Permittee shall submit a report to NMED with the next monitoring report following the repair that includes a description of the malfunction; a statement verifying the repair; and a flow meter field calibration report completed in accordance with the requirements of this Discharge Permit. For <i>replacement</i> meters, the Permittee shall submit a report to NMED with the next monitoring report following the replacement that includes a design schematic for the device and a flow meter field calibration report completed in accordance with the requirements of this Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
30.	<p>The Permittee shall collect samples of reclaimed domestic wastewater from the UV disinfection unit on a quarterly basis and analyze the samples for:</p> <ul style="list-style-type: none"> TKN; NO₃-N;

#	Terms and Conditions
	<ul style="list-style-type: none"> • TDS; and • Cl. <p>The Permittee shall ensure the samples are properly prepared, preserved, transported, and analyzed in accordance with the methods authorized in this Discharge Permit. The Permittee shall submit the laboratory analytical data results, including the QA/QC summary and Chain of Custody, to NMED in the subsequent quarterly monitoring report.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
31.	<p>During any week that the discharge of reclaimed domestic wastewater occurs, the Permittee shall perform the following analyses on the wastewater samples collected at following the UV disinfection system using the following sampling method and frequency:</p> <ul style="list-style-type: none"> • Fecal coliform or E. coli bacteria: grab sample at peak daily flow three times per week; • BOD₅: six-hour composite sample three times per week; • TSS: six-hour composite sample three times per week; and • UV transmissivity values: record whenever collecting bacteria samples. <p>The Permittee shall ensure the samples are properly prepared, preserved, transported and analyzed in accordance with the methods authorized in this Discharge Permit. The Permittee shall submit the laboratory analytical data results, including the QA/QC summary and Chain of Custody, and a copy of the log of UV transmissivity values to NMED in the subsequent quarterly monitoring report.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections B, C and H of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p>
32.	<p>Once during the term of this Discharge Permit, the Permittee shall collect a 24-hour flow weighted composite sample (except as noted for pH) of reclaimed domestic wastewater following the UV disinfection unit and analyze the sample for the following inorganic contaminants (dissolved fraction, except as noted):</p> <ul style="list-style-type: none"> • aluminum (CAS 7429-90-5) • antimony (CAS 7440-36-0) • arsenic (CAS 7440-38-2) • barium (CAS 7440-39-3) • beryllium (CAS 7440-41-7) • boron (CAS 7440-42-8) • cadmium (CAS 7440-43-9) • chromium (CAS 7440-47-3) • molybdenum (CAS 7439-98-7) • total mercury (nonfiltered) (CAS 7439-97-6) • pH (instantaneous) • nickel (CAS 7440-02-0) • radioactivity: combined radium-226 & radium-228 (CAS 15262-20-1) • selenium (CAS 7782-49-2)

#	Terms and Conditions
	<ul style="list-style-type: none"> • cobalt (CAS 7440-48-4) • copper (CAS 7440-50-8) • cyanide (CAS 57-12-5) • fluoride (CAS 16984-48-8) • iron (CAS 7439-89-6) • lead (CAS 7439-92-1) • manganese (CAS 7439-96-5) • silver (CAS 7440-224) • sulfate (CAS 14808-79-8) • thallium (CAS 7440-28-0) • uranium (CAS 7440-61-1) • zinc (CAS 7440-66-6) <p>The Permittee shall properly collect, prepare, preserve, transport and analyze the samples in accordance with the methods authorized in this Discharge Permit. The Permittee shall analyze the sample using methods with reporting limits that are less than the corresponding numerical groundwater standards identified in 20.6.2.3103 NMAC.</p> <p>The Permittee shall submit a summary of measured concentrations compared with the corresponding groundwater standards, a copy of the laboratory report including the laboratory analytical data results, the QA/QC summary and the Chain of Custody, to NMED in the monitoring report due by August 1st of the year sampling occurs.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
33.	<p>Once during the term of this Discharge Permit the Permittee shall collect a grab sample of reclaimed domestic wastewater following the UV disinfection unit and analyze the non-filtered sample for the following organic contaminants:</p> <ul style="list-style-type: none"> • atrazine (CAS 1912-24-9) • benzene (CAS 71-43-2) • benzo-a-pyrene (CAS 50-32-8) • carbon tetrachloride (CAS 56-23-5) • chloroform (CAS 67-66-3) • 1,2-dichlorobenzene (CAS 95-50-1) • 1,4-dichlorobenzene (CAS 106-46-7) • 1,1-dichloroethane (CAS 75-34-3) • 1,2-dichloroethane (EDC, CAS 107-06-2) • ethylene dibromide (EDB, CAS 106-93-4) • methylene chloride (CAS 75-09-2) • <u>PAHs</u>: total naphthalene (CAS 91-20-3) plus monomethylnaphthalenes • phenols • polychlorinated biphenyls (PCBs, CAS 1336-36-3) • pentachlorophenol (CAS 87-86-5) • toluene (CAS 108-88-3) • styrene (CAS 100-42-5) • 1,1,2,2-tetrachloroethane (CAS 79-34-5)

#	Terms and Conditions
	<ul style="list-style-type: none"> • 1,1-dichloroethene (1,1-DCE, CAS 75-35-4) • cis-1,2-dichloroethene (CAS 156-59-2) • trans-1,2-dichloroethene (CAS 156-60-5) • 1,2-dichloropropane (PDC, CAS 78-87-5) • 1,4-dioxane (CAS 123-91-1) (using EPA Method 8270D-SIM) • ethylbenzene (CAS 100-41-4) • tetrachloroethene (PCE, CAS 127-18-4) • 1,2,4-trichlorobenzene (CAS 120-82-1) • 1,1,1-trichloroethane (1,1,1-TCA, CAS 71-55-6) • 1,1,2-trichloroethane (CAS 79-00-5) • trichloroethene (TCE, CAS 79-01-6) • vinyl chloride (CAS 75-01-4) • total xylenes (CAS 1330-20-7) <p>The Permittee shall properly collect, prepare, preserve, transport and analyze the samples in accordance with the methods authorized in this Discharge Permit. The Permittee shall analyze samples using methods with reporting limits that are less than the corresponding numerical groundwater standards identified in 20.6.2.3103 NMAC. The reporting limit for 1,4-dioxane shall be less than the Tap Water Screening Level for 1,4-dioxane identified in the <i>NMED Risk Assessment Guidance for Site Assessments and Investigations</i>, Table A-1 (available on the NMED Hazardous Waste Bureau's website under Guidance Documents).</p> <p>If the results of two consecutive sampling events indicate no detection of 1,4-dioxane above the reporting limit, the Permittee may request to reduce the sampling frequency.</p> <p>The Permittee shall submit a summary of measured concentrations compared with the corresponding groundwater standards, and a copy of the laboratory report including the laboratory analytical data results, the QA/QC summary and the Chain of Custody to NMED in the monitoring report due by August 1st of the year sampling occurred.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p>
34.	<p>On an annual basis, the Permittee shall collect a grab sample of untreated wastewater from the inlet of the treatment facility (prior to any treatment) and analyze the sample for fats, oils and grease (FOG).</p> <p>The Permittee shall ensure the sample is properly prepared, preserved, transported and analyzed in accordance with the methods authorized in this Discharge Permit. The Permittee shall submit the laboratory analytical data results, QA/QC summary, and the Chain of Custody to NMED in the monitoring reports due by August 1st each year.</p>

#	Terms and Conditions
	[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]
35.	<p>The Permittee shall complete LADS (copy enclosed) on a monthly basis that document the amount of nitrogen applied to Anthony W&SD owned flood/drip irrigation re-use areas during the most recent 12 months. The LADS shall reflect the total nitrogen concentration from the most recent wastewater analysis and the measured discharge volumes to Anthony WS&D owned re-use areas for each month. The Permittee shall complete the LADS with the information above or include a statement that the discharge of treated wastewater did not occur. The Permittee shall submit the LADS to NMED in the subsequent quarterly monitoring report.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
36.	<p>The Permittee shall submit records of solids disposal, including a copy of all Discharge Monitoring Reports (i.e., DMRs) required by the EPA pursuant to 40 CFR 503, for the previous calendar year, to NMED annually in the monitoring report due by August 1st each year.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>

C. CONTINGENCY PLAN

#	Terms and Conditions
37.	<p>In the event that groundwater monitoring indicates that groundwater exceeds a standard identified in Section 20.6.2.3103 NMAC in a monitoring well with no previous exceedances of the chemical constituent at the date of issuance of this Discharge Permit, the Permittee shall collect a confirmatory sample from the monitoring well within 15 days of receipt of the initial sampling results to confirm the initial sampling results.</p> <p>Within 60 days of confirmation of groundwater contamination, the Permittee shall submit to NMED a Corrective Action Plan (CAP) that proposes, at a minimum, contaminant source control measures and an implementation schedule. The Permittee shall implement the CAP as approved by NMED.</p> <p>Once this groundwater exceedance response condition is invoked whether during the term of this Discharge Permit or after the term of this Discharge Permit and prior to the completion of the Discharge Permit closure plan requirements, this condition shall apply until the Permittee has fulfilled the requirements of this condition and groundwater monitoring confirms for a minimum of eight (8) consecutive quarterly samples that groundwater does not exceed the standards of Section 20.6.2.3103 NMAC.</p>

#	Terms and Conditions
	<p>Violation of the groundwater standard beyond 180 days after the confirmation of groundwater contamination may cause NMED to require the Permittee to abate water pollution consistent with the requirements and provisions of Section 20.6.2.4101, Section 20.6.2.4103, Subsections C and E of 20.6.2.4106, Section 20.6.2.4107, Section 20.6.2.4108 and Section 20.6.2.4112 NMAC.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection E of 20.6.2.3109 NMAC]</p>
38.	<p>In the event that information available to NMED indicates that a well is not constructed in a manner consistent with the attached Monitoring Well Guidance; contains insufficient water to effectively monitor groundwater quality; or is otherwise not completed in a manner that is protective of groundwater quality, the Permittee shall install a replacement well(s) within 120 days following notification from NMED.</p> <p>The Permittee shall survey the replacement monitoring well(s) within 150 days following notification from NMED</p> <p>The Permittee shall install replacement wells at locations approved by NMED prior to installation and shall complete replacement wells in accordance with the Monitoring Well Guidance. The Permittee shall submit well construction and lithologic logs survey data and a groundwater elevation contour map to NMED within 60 days following well completion.</p> <p>The Permittee shall properly plug and abandon a monitoring well requiring replacement upon completion of the replacement monitoring well. The Permittee shall complete the well plugging and abandonment, and shall document the abandonment procedures, in accordance with the Monitoring Well Guidance and all applicable local, state, and federal regulations. The Permittee shall submit a copy of the well abandonment documentation to NMED within 60 days following the replacement well completion.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
39.	<p>In the event that groundwater flow information obtained pursuant to this Discharge Permit indicates that a monitoring well is not appropriately located, e.g., hydrologically downgradient of the discharge location it is intended to monitor, the Permittee shall install a replacement well within 120 days following notification from NMED. The Permittee shall survey the replacement monitoring well within 30 days following well completion.</p>

#	Terms and Conditions
	<p>The Permittee shall install replacement wells at locations approved by NMED prior to installation and shall complete replacement wells in accordance with the attached Monitoring Well Guidance. The Permittee shall submit construction and lithologic logs, survey data and a groundwater elevation contour map within 60 days following well completion.</p> <p>The Permittee shall properly plug and abandon a monitoring well requiring replacement upon completion of the replacement monitoring well. The Permittee shall complete the well plugging and abandonment, and shall document the abandonment procedures, in accordance with the Monitoring Well Guidance and all applicable local, state, and federal regulations. The Permittee shall submit a copy of the well abandonment documentation to NMED within 60 days following the replacement well completion.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
40.	<p>In the event that analytical results of a treated wastewater sample indicate an exceedance of the total nitrogen discharge limit set in this Discharge Permit, the Permittee shall collect and submit for analysis a second sample within 48 hours of the receipt of the initial sampling results. In the event the second sample results indicate an exceedance of the discharge limit, the Permittee shall implement the following contingencies.</p> <ol style="list-style-type: none">a) Within 7 days of the second sample analysis date indicating exceedance of the discharge limit, the Permittee shall:<ol style="list-style-type: none">i) notify NMED that the Permittee is implementing the Contingency Plan; andii) submit a copy of the first and second analytical results indicating an exceedance to NMED.b) The Permittee shall increase the frequency of total nitrogen wastewater sampling and analysis of treated wastewater to once per month.c) The Permittee shall examine the operation and maintenance log, required by the Record Keeping conditions of this Discharge Permit, for improper operational procedures.d) The Permittee shall conduct a physical inspection of the treatment system to detect abnormalities. The Permittee shall correct any abnormalities discovered. The Permittee shall submit a report to NMED detailing the corrections within 30 days of correction.e) In the event that any analytical results from monthly wastewater sampling indicate an exceedance of the total nitrogen discharge limit, the Permittee shall submit a CAP to NMED for approval proposing to modify operational procedures and/or upgrade the treatment process to achieve the total nitrogen limit. The Permittee shall submit the CAP including a schedule for completion of corrective actions and within 90 days of receipt of the analytical results of the second sample indicating that the discharge limit is continuing to be exceeded. The Permittee shall initiate implementation of the

#	Terms and Conditions
	<p>CAP following approval by NMED.</p> <p>When analytical results from three consecutive months of wastewater sampling do not exceed the discharge limit, the Permittee may request NMED authorize a return to a quarterly monitoring frequency.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
41.	<p>In the event that analytical results of a reclaimed domestic wastewater sample indicate an exceedance of any of the maximum discharge limits for BOD₅, [TSS/turbidity], or fecal coliform or E. coli bacteria set by this Discharge Permit, the Permittee shall collect and submit for analysis a second sample within 24 hours after becoming aware of the exceedance. In the event the second sample results confirm the exceedance of the maximum discharge limits, the Permittee shall implement the Contingency Plan below.</p> <p>In the event that analytical results of a reclaimed domestic wastewater sample indicate an exceedance of any of the 30-day average discharge limits for BOD₅, TSS, or fecal coliform or E. coli bacteria set by this Discharge Permit (i.e., confirmed exceedance), the Permittee shall implement the Contingency Plan below.</p> <p><u>Contingency Plan</u></p> <ol style="list-style-type: none">a) Within 24 hours of becoming aware of a confirmed exceedance (as identified above), the Permittee shall:<ol style="list-style-type: none">i) notify NMED that the Permittee is implementing the Contingency Plan; andii) submit copies of the recent analytical results indicating an exceedance to NMED.b) The Permittee shall immediately cease discharging reclaimed domestic wastewater to the reuse area if the fecal coliform or E. coli bacteria maximum limit is exceeded.c) The Permittee shall examine the operation and maintenance log, required by the Record Keeping conditions of this Discharge Permit, for improper operational procedures.d) The Permittee shall conduct a physical inspection of the treatment system to detect abnormalities and shall correct any abnormalities discovered. The Permittee shall submit a report detailing the corrections made to NMED within 30 days following correction. <p>When the analytical results from samples of reclaimed domestic wastewater, sampled as required by this Discharge Permit, no longer indicate an exceedance of any of the maximum discharge limits, the Permittee may resume discharging reclaimed domestic wastewater to the reuse area.</p>

#	Terms and Conditions
	<p>If a Facility is required to implement the Contingency Plan more than two times in a 12-month period, the Permittee shall propose to modify operational procedures and/or upgrade the treatment process to achieve consistent compliance with the maximum and 30-day average discharge limits by submitting a Corrective Action Plan (CAP) for NMED approval. The Permittee shall ensure the CAP includes a schedule for completion of corrective actions and submit the CAP within 60 days following receipt of the analytical results confirming the exceedance. The Permittee shall initiate implementation of the CAP following approval by NMED. NMED may require, prior to recommencing discharge to the reuse area, additional sampling of any stored reclaimed domestic wastewater.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
42.	<p>In the event that an inspection reveals significant damage has occurred or is likely to affect the structural integrity of an paved drying bed or their ability to contain contaminants, the Permittee shall propose the repair or replacement by submitting a CAP to NMED for approval. The Permittee shall submit the CAP to NMED within 30 days after discovery of the damage or following notification from NMED that significant damage is evident. The Permittee shall ensure the CAP includes a schedule for completion of corrective actions. The Permittee shall initiate implementation of the CAP following approval by NMED.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
43.	<p>In the event that the LADS (copy enclosed) show that the amount of nitrogen in wastewater applied in any 12-month period exceeds 200 pounds per acre, the Permittee shall propose the reduction of nitrogen loading to Anthony W&SD owned reuse areas by submitting a Corrective Action Plan (CAP) to NMED for approval. The Permittee shall ensure the CAP includes a schedule for completion of corrective actions and submit the CAP within 90 days following the end of the monitoring period in which the exceedance occurred. The Permittee shall implement the CAP following approval by NMED.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p>
44.	<p>In the event that a release occurs that is not authorized under this Discharge Permit (commonly known as a “spill”), the Permittee shall take measures to mitigate damage from the unauthorized discharge and initiate the notifications and corrective actions required in Section 20.6.2.1203 NMAC and summarized below. A release is defined as such quantity as may with reasonable probability injure or be detrimental to human health, animal or plant life, or property, or unreasonably interfere with the public welfare or the use of property.</p> <p>Within <u>24 hours</u> following discovery of the unauthorized discharge, the Permittee shall verbally notify NMED and provide the following information.</p>

#	Terms and Conditions
	<ul style="list-style-type: none">a) The name, address, and telephone number of the person or persons in charge of the Facility, as well as of the owner and/or operator of the Facility.b) The name and address of the Facility.c) The date, time, location, and duration of the unauthorized discharge.d) The source and cause of unauthorized discharge.e) A description of the unauthorized discharge, including its estimated chemical composition.f) The estimated volume of the unauthorized discharge.g) Any actions taken to mitigate immediate damage from the unauthorized discharge. <p>Within <u>one week</u> following discovery of the unauthorized discharge, the Permittee shall submit written notification to NMED providing the information listed above and any pertinent updates.</p> <p>Within <u>15 days</u> following discovery of the unauthorized discharge, the Permittee shall submit a Corrective Action Plan (CAP) to NMED describing any corrective actions previously taken and corrective actions to be taken relative to the unauthorized discharge. The CAP shall include the following information.</p> <ul style="list-style-type: none">a) A description of proposed actions to mitigate damage from the unauthorized discharge.b) A description of proposed actions to prevent future unauthorized discharges of this nature.c) A schedule for completion of proposed actions. <p>In the event that the unauthorized discharge causes or may with reasonable probability cause water pollution in excess of the standards and requirements of Section 20.6.2.4103 NMAC, and the water pollution will not be abated within 180 days after notice is required to be given pursuant to Paragraph (1) of Subsection A of 20.6.2.1203 NMAC, NMED may require the Permittee to abate water pollution pursuant to Sections 20.6.2.4000 through 20.6.2.4115 NMAC.</p> <p>The Permittee shall not construe anything in this condition as relieving them of the obligation to comply with all requirements of Section 20.6.2.1203 NMAC.</p> <p>[20.6.2.1203 NMAC]</p>
45.	<p>In the event that NMED or the Permittee identifies any failures of the discharge plan, i.e., the application, or this Discharge Permit not specifically noted herein, NMED may require the Permittee to submit a CAP and a schedule for completion of corrective actions to address the failure(s). Additionally, NMED may require a discharge permit modification to achieve compliance with 20.6.2 NMAC.</p>

#	Terms and Conditions
	[Subsection A of 20.6.2.3107 NMAC, Subsection E of 20.6.2.3109 NMAC]

D. CLOSURE PLAN

Permanent Facility Closure Conditions

#	Terms and Conditions
46.	<p>The Permittee shall perform the following closure measures in the event the Facility, or a component of the Facility, is proposed to be permanently closed.</p> <p>Within <u>90 days</u> of ceasing to discharge to the treatment system, the Permittee shall complete the following closure measures.</p> <ul style="list-style-type: none">a) Plug the line leading to the system so that a discharge can no longer occur.b) Evaporate wastewater in the system components or drain and dispose of in accordance with all local, state, and federal regulations.c) Contain, transport, and dispose of solids removed from the treatment system in accordance with all local, state, and federal regulations, including 40 CFR Part 503. The Permittee shall maintain a record of all solids transported for off-site disposal. <p>Within <u>180 days</u> of ceasing to discharge to the treatment system (or unit), the Permittee shall complete the following closure measures.</p> <ul style="list-style-type: none">a) Remove all lines leading to and from the treatment system, or permanently plug and abandon them in place.b) Remove or demolish all treatment system components, and re-grade the area with suitable fill to blend with surface topography, promote positive drainage and prevent ponding. <p>The Permittee shall continue groundwater monitoring until the Permittee meets the requirements of this condition and groundwater monitoring confirms for a minimum of eight consecutive quarterly groundwater sampling events that groundwater does not exceed the standards of Section 20.6.2.3103 NMAC. This period is referred to as “post-closure.”</p> <p>If at any time monitoring results show an exceedance of a groundwater quality standard in Section 20.6.2.3103 NMAC, the Permittee shall implement the Contingency Plan required by this Discharge Permit.</p> <p>Following notification from NMED that the Permittee may cease post-closure monitoring,</p>

#	Terms and Conditions
	<p>the Permittee shall plug and abandon the monitoring well(s) in accordance with the attached Monitoring Well Guidance.</p> <p>When the Permittee has met all closure and post-closure requirements and verified appropriate actions with date stamped photographic evidence or an associated NMED inspection, the Permittee may submit to NMED a written request, including photographic evidence, for termination of the Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection D of 20.6.2.4103 NMAC, 40 CFR Part 503]</p>

E. GENERAL TERMS AND CONDITIONS

#	Terms and Conditions
47.	<p>RECORD KEEPING - The Permittee shall maintain a written record of the following:</p> <ul style="list-style-type: none">• Information and data used to complete the application for this Discharge Permit;• Information, data, and documents demonstrating completion of closure activities;• Any releases (commonly known as “spills”) not authorized under this Discharge Permit and reports submitted pursuant to 20.6.2.1203 NMAC;• The operation, maintenance, and repair of all facilities/equipment used to treat, store or dispose of wastewater;• Facility record drawings (plans and specifications) showing the actual construction of the Facility and bear the seal and signature of a licensed New Mexico professional engineer;• Copies of logs, inspection reports, and monitoring reports completed and/or submitted to NMED pursuant to this Discharge Permit;• The volume of wastewater or other wastes discharged pursuant to this Discharge Permit;• Groundwater quality and wastewater quality data collected pursuant to this Discharge Permit;• Copies of construction records (well log) for all sampled groundwater monitoring wells pursuant to this Discharge Permit;• The maintenance, repair, replacement or calibration of any monitoring equipment or flow measurement devices required by this Discharge Permit; and• Data and information related to field measurements, sampling, and analysis conducted pursuant to this Discharge Permit, including:<ul style="list-style-type: none">○ the dates, location and times of sampling or field measurements;○ the name and job title of the individuals who performed each sample collection or field measurement;

#	Terms and Conditions
	<ul style="list-style-type: none"> ○ the sample analysis date of each sample ○ the name and address of the laboratory, and the name of the signatory authority for the laboratory analysis; ○ the analytical technique or method used to analyze each sample or collect each field measurement; ○ the results of each analysis or field measurement, including raw data; ○ the results of any split, spiked, duplicate or repeat sample; and ○ a copy of the laboratory analysis chain-of-custody as well as a description of the quality assurance and quality control procedures used. <p>The Permittee shall maintain the written record at a location accessible to NMED during a Facility inspection for the lifetime of the Discharge Permit. The Permittee shall make the record available to the department upon request.</p> <p>[Subsections A and D of 20.6.2.3107 NMAC]</p>
48.	<p>SUBMITTALS – The Permittee shall submit both a paper copy and an electronic copy of all notification and reporting documents required by this Discharge Permit, e.g., monitoring reports. The Permittee shall submit paper and electronic documents to the NMED Permit Contact identified on the Permit cover page.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p>
49.	<p>INSPECTION and ENTRY – The Permittee shall allow NMED to inspect the Facility and its operations that are subject to this Discharge Permit and the WQCC regulations. NMED may upon presentation of proper credentials, enter at reasonable times upon or through any premises in which a water contaminant source is located or in which any maintained records required by this Discharge Permit, the regulations of the federal government, or the WQCC are located.</p> <p>The Permittee shall allow NMED to have access to and reproduce for their use any copy of the records, and to perform assessments, sampling or monitoring during an inspection for the purpose of evaluating compliance with this Discharge Permit and the WQCC regulations.</p> <p>No person shall construe anything in this Discharge Permit as limiting in any way the inspection and entry authority of NMED under the WQA, the WQCC Regulations, or any other local, state or federal regulations.</p> <p>[Subsection D of 20.6.2.3107 NMAC, NMSA 1978, §§ 74-6-9.B and 74-6-9.E]</p>

#	Terms and Conditions
50.	<p>DUTY to PROVIDE INFORMATION - The Permittee shall, upon NMED's request, allow for NMED's inspection/duplication of records required by this Discharge Permit and/or furnish to NMED copies of such records.</p> <p>[Subsection D of 20.6.2.3107 NMAC]</p>
51.	<p>MODIFICATIONS and/or AMENDMENTS – In the event the Permittee proposes a change to the Facility or the Facility's discharge that would result in a change in the volume discharged; the location of the discharge; or in the amount or character of water contaminants received, treated or discharged by the Facility, the Permittee shall notify NMED prior to implementing such changes. The Permittee shall obtain NMED's approval (which may require modification of this Discharge Permit) prior to implementing such changes.</p> <p>[Subsection C of 20.6.2.3107 NMAC, Subsections E and G of 20.6.2.3109 NMAC]</p>
52.	<p>PLANS and SPECIFICATIONS – In the event the Permittee proposes to construct a wastewater system or change a process unit of an existing system such that the quantity or quality of the discharge will change substantially from that authorized by this Discharge Permit, the Permittee shall submit construction plans and specifications of the proposed system or process unit to NMED for approval prior to the commencement of construction.</p> <p>In the event the Permittee implements changes to the wastewater system authorized by this Discharge Permit that result in only a minor effect on the character of the discharge, the Permittee shall report such changes (including the submission of record drawings where applicable) to NMED prior to implementation.</p> <p>[Subsections A and C of 20.6.2.1202 NMAC, NMSA 1978, §§ 61-23-1 through 61-23-32]</p>
53.	<p>CIVIL PENALTIES - Any violation of the requirements and conditions of this Discharge Permit, including any failure to allow NMED staff to enter and inspect records or facilities, or any refusal or failure to provide NMED with records or information, may subject the Permittee to a civil enforcement action. Pursuant to WQA 74-6-10(A) and (B), such action may include a compliance order requiring compliance immediately or in a specified time, assessing a civil penalty, modifying or terminating the Discharge Permit, or any combination of the foregoing; or an action in district court seeking injunctive relief, civil penalties, or both. Pursuant to WQA 74-6-10(C) and 74-6-10.1, civil penalties of up to \$15,000 per day of noncompliance may be assessed for each violation of the WQA 74-6-5, the WQCC Regulations, or this Discharge Permit, and civil penalties of up to \$10,000 per day of noncompliance may be assessed for each violation of any other provision of the WQA, or any regulation, standard, or order adopted pursuant to such other provision.</p>

#	Terms and Conditions
	<p>In any action to enforce this Discharge Permit, the Permittee waives any objection to the admissibility as evidence of any data generated pursuant to this Discharge Permit.</p> <p>[20.6.2.1220 NMAC, NMSA 1978, §§ 74-6-10 and 74-6-10.1]</p>
54.	<p>CRIMINAL PENALTIES – No person shall:</p> <ul style="list-style-type: none">• Make any false material statement, representation, certification or omission of material fact in an application, record, report, plan or other document filed, submitted or maintained under the WQA;• Falsify, tamper with or render inaccurate any monitoring device, method or record maintained under the WQA; or• Fail to monitor, sample or report as required by a permit issued pursuant to a state or federal law or regulation. <p>Any person who knowingly violates or knowingly causes or allows another person to violate the requirements of this condition is guilty of a fourth-degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who is convicted of a second or subsequent violation of the requirements of this condition is guilty of a third-degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who knowingly violates the requirements of this condition or knowingly causes another person to violate the requirements of this condition and thereby causes a substantial adverse environmental impact is guilty of a third-degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who knowingly violates the requirements of this condition and knows at the time of the violation that he is creating a substantial danger of death or serious bodily injury to any other person is guilty of a second degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15.</p> <p>[20.6.2.1220 NMAC, NMSA 1978, §§ 74-6-10.2.A through 74-6-10.2.F]</p>
55.	<p>COMPLIANCE with OTHER LAWS - Nothing in this Discharge Permit shall be construed in any way as relieving the Permittee of the obligation to comply with any other applicable federal, state, and/or local laws, regulations, zoning requirements, nuisance ordinances, permits or orders.</p> <p>[NMSA 1978, § 74-6-5.L]</p>
56.	<p>RIGHT to APPEAL - The Permittee may file a petition for review before the WQCC on this Discharge Permit. Such petition shall be in writing to the WQCC within thirty days of the receipt of postal notice of this Discharge Permit and shall include a statement of the</p>

#	Terms and Conditions
	<p>issues raised and the relief sought. Unless the Permittee files a timely petition for review, the decision of NMED shall be final and not subject to judicial review.</p> <p>[20.6.2.3112 NMAC, NMSA 1978, § 74-6-5.O]</p>
57.	<p>TRANSFER of DISCHARGE PERMIT - Prior to the transfer of any ownership, control, or possession of this Facility or any portion thereof, the Permittee shall:</p> <ul style="list-style-type: none">• Notify the proposed transferee in writing of the existence of this Discharge Permit;• Include a copy of this Discharge Permit with the notice; and• Deliver or send by certified mail to NMED a copy of the notification and proof that the proposed transferee has received such notification. <p>The Permittee shall continue to be responsible for any discharge from the Facility, until both ownership and possession of the Facility have been transferred to the transferee.</p> <p>[20.6.2.3111 NMAC]</p>
58.	<p>PERMIT FEES – The Permittee shall be aware that the payment of permit fees is due at the time of Discharge Permit approval. The Permittee may pay the permit fees in a single payment or they may pay the fee in equal installments on a yearly basis over the term of the Discharge Permit. The Permittee shall remit single payments to NMED no later than 30 days after the Discharge Permit issuance date. The Permittee shall remit initial installment payments to NMED no later than 30 days after the Discharge Permit issuance date; with subsequent installment payments remitted to NMED no later than the anniversary of the Discharge Permit issuance date.</p> <p>Permit fees are associated with <u>issuance</u> of this Discharge Permit. No person shall construe anything in this Discharge Permit as relieving the Permittee of the obligation to pay all permit fees assessed by NMED. A Permittee that ceases discharging or does not commence discharging from the Facility during the term of the Discharge Permit shall pay all permit fees assessed by NMED. NMED shall suspend or terminate an approved Discharge Permit if the Permittee fails to remit an installment payment by its due date.</p> <p>[Subsection F of 20.6.2.3114 NMAC, NMSA 1978, § 74-6-5.K]</p>



New Mexico Environment Department Ground Water Quality Bureau Discharge Permit Summary

Facility Information

Facility Name Anthony Wastewater Treatment Facility
Discharge Permit Number DP-450
Legally Responsible Party Jose Terrones, Superintendent
Anthony Water and Sanitation District
P.O. Box 1751
Anthony, NM 88021
(575) 882-3922

Treatment, Disposal and Site Information

Primary Waste Type Domestic
Facility Type Municipal Wastewater Treatment Plant (WWTP)

Treatment Methods

Type	Designation	Description & Comments
Wastewater Treatment System	Anthony Municipal WWTP	Activated sludge extended aeration with UV disinfection

Discharge Locations

Type	Designation	Description & Comments
Sludge Drying Beds	Storage ponds	Backup for belt press
Re-use Area	WWTP	Flood or drip irrigation of the WWTP grounds
Surface Water	Rio Grande	NPDES permit number NM0029629

Flow Metering Locations

Type	Designation	Description & Comments
Totalizing Flow Meter	Influent	Flow meter and recorder for influent to the WWTP
Totalizing Flow Meter	Irrigation	Reclaimed effluent used for irrigating WWTP grounds
Totalizing Flow Meter	Transfer from the chlorine contact chamber	Reclaimed wastewater transferred to other separately permitted entities for irrigation or for temporary uses not requiring a discharge permit

Ground Water Monitoring Locations

Type	Designation	Description & Comments
Monitoring Well	MW-1	Upgradient of the facility at 32.02252 -106.59865 in the northeast corner of the WWTP
Monitoring Well	MW-2	Hydrologically downgradient of small storage lagoon at 32.02156 -106.59979



New Mexico Environment Department Ground Water Quality Bureau Discharge Permit Summary

Monitoring Well	MW-3a	Located at an alternate location from MW-2 and hydrologically downgradient of the UV disinfection unit
-----------------	-------	--

Depth-to-Ground Water 55 feet
Total Dissolved Solids (TDS) 1,160 mg/L

Permit Information

Original Permit Issued January 9, 1987
Permit Renewal September 23, 1992
Permit Renewal July 20, 1998
Permit Renewal March 29, 2004
Permit Renewal October 18, 2013
Permit Renewal August 1, 2019

Current Action

Application Received
Public Notice Published
Permit Issued (Issuance Date)
Permitted Discharge Volume

Permit Renewal and Modification

August 18, 2021
September 23, 2022
[issuance date]
1.3 MGD gallons per day

NMED Contact Information

Mailing Address

Ground Water Quality Bureau
P.O. Box 5469
Santa Fe, New Mexico 87502-5469

GWQB Telephone Number

(505) 827-2900

NMED Lead Staff

Lead Staff Telephone Number

Lead Staff Email

Aracely Tellez
(505) 629-8864
aracely.tellez@state.nm.us or pps.general@state.nm.us